

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 822 / UJS / DLWQTML / 2025 - 26

Dated: 12/06/25

It is certified that an inspection team headed by DR. VIKASH KHANDARI [CHIEF CHEMIST]

(Name of Officers with designation) from UTTARAKHAND JAL SANSTHAN PHED

inspected the SIERRA INTERNATIONAL SCHOOL, MATHROWALA, DEHRADUN

(Name & Address of the school) on 06/06/25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 822 / UJS / DLWQTML / 25 dated 12/06/25

of DISTRICT WATER TESTING LAB (PHED Lab) certified that the

SIERRA INTERNATIONAL SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till FOR 06 MONTH

Signature with Seal:

Name

Designation

Name & Address of the Office / Department : UJS, DEHRADUN

DAV VIKASH KHANDARI
TECHNICAL MANAGER

To

SIERRA INTERNATIONAL
SCHOOL, MATHROWALA, DEHRADUN
(Name & Address of the Institution)

Authorized Signatory
DLWQTML
Uttarakhand Jal Sansthan
Dehradun

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Neha
Principal
Sierra International School

Manager
Sierra International School
Mothrowala, Dehradun.



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun



TC-13625

TEST REPORT

Name and Address of Organization/ Customer	Sierra International School, Mathrowala, Dehradun, Uttarakhand.		
Test Report ID	822/UJS/DLWQTML/2025-26	Reporting Date	12/06/2025
ULR No.	TC13625250000000000225F	Sample Location	Mathrowala, Dehradun, Uttarakhand
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2025-822		
Date of Start of Analysis:	06/06/2025		
Date of End of Analysis:	12/06/2025		
Date and Time of Sample Received:	06/06/25 & 02 08 PM		


SN	Parameters	Test Method	Result	Acceptable Limit As per (IS 10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
(A) Organoleptic and Physical Parameters					
1.	pH at 25°C	IS 3025 (Part 11) 2022	7.26	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C mg/L	IS 3025 (Part 16), 2023	264	500 Max	2000 Max
3.	Turbidity, NTU, Max	IS 3025 (Part 10), 2023	0.89	1 Max	5 Max
4.	Colour, Hazen	IS 3025 (Part 4): 2021	Less than 01	5 Max	15 Max
5.	Odour	IS 3025 (Part 5) - 2018	Agreeable	Agreeable	Agreeable
(B) General Parameters Concerning Substances					
6.	Total Alkalinity (as CaCO ₃), mg/L	IS 3025 (Part 23), 2023	156	200 Max	600 Max
7.	Total Hardness (as CaCO ₃), mg/L	IS 3025 (Part 21), 2009	182	200 Max	600 Max
8.	Calcium as Ca, mg/l	IS 3025 (Part 40), 2019	31.2	75 Max	200 Max
9.	Chloride, mg/L	IS 3025 (Part 32), 2019	22	250 Max	1000 Max
10.	Magnesium as Mg, mg/l	APHA 24 th Ed -3500-Mg Method B:2023 (Calculation Method)	25.27	30 Max	100 Max
(D) Microbiological Parameters					
S.n.	Parameters	Test method	Results	Requirements as per IS 10500:2012	
11.	Total Coliform (in 100ml)	IS 15185:2016	Absent	Shall not be detectable in any 100 ml sample	
12.	E. coli, (in 100ml)	IS 15185:2016	Absent	Shall not be detectable in any 100 ml sample	

Note -

- The results listed refer only to tested sample and applicable parameters
- This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
- The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
- The results apply to the sample as received
- The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

Review and Authorized By


(Dr. Vikash Kantari)

Technical Manager, Lab
Authorized Signatory
DLWQTML

Uttarakhand Jal Sansthan

Dehradun

Format No. UJS/LMSTRC-01

Page 01 of 01


Principal
Sierra International School


Manager
Sierra International School
Mathrowala, Dehradun.

Scanned with OKEN Scanner



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun

TEST REPORT

Name and Address of Organization/ Customer	Sierra International School, Mathrowala, Dehradun, Uttarakhand.		
Test Report ID	822A/UJS/DLWQTML/2025-26	Reporting Date	12/06/2025
		Sample Location	Mathrowala, Dehradun, Uttarakhand
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2025-822		
Date of Start of Analysis:	06/06/2025		
Date of End of Analysis:	12/06/2025		
Date and Time of Sample Received:	06/06/25 & 02:08 PM		

SN	Parameters	Test Method	Results	Acceptable Limit As per (IS 0500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
----	------------	-------------	---------	--	--

(C) General Parameters Concerning Substances


1	Fluoride, mg/L, Max	APHA 23rd Ed 4500-F-D 2023	0.10	1.0	1.5
2	Nitrate, mg/L, Max	APHA 23rd Ed 4500-NO ₃ -B 2023	2.40	45	No Relaxation
3	Sulfate, mg/L, Max	APHA 23rd Ed 4500-SO ₄ -F 2023	6.32	200	100

Note -

1. The results listed refer only to tested sample and applicable parameters
2. This certificate is not to be reproduced wholly or in parts for promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

Review and Authorized By


Dr. Vikash Kandari

Technical Manager, Lab
Authorized Signatory
DLWQTML
Uttarakhand Jal Sansthan
Dehradun


Principal
Sierra International School


Manager
Sierra International School
Mathrowala, Dehradun.